



SZUTEST
NOTIFIED BODY 2195

AB-TASARIM İNCELEME BELGESİ

EU Design Examination Certificate

2014/33/AB Asansör Yönetmeliği Ek XI Madde 3.3'e göre
2014/33/EU Lift Directive Annex XI Article 3.3 has been taken as reference for these processes.

No: **2195-LD-17011107**

Monte Eden Firma : MFG MÜHENDİSLİK ASANSÖR MAK. ELEKTRİK İNŞ. SAN. VE
Installer's Name TİC.LTD.ŞTİ.

Adresi : Orhan Gazi Mah. Adnan Menderes Bulvarı Beyza Apt. Altı No:35/ A
Address Kahramanmaraş, Türkiye

Standarttan Sapma : Makine Dairesi Boyutlarının yetersiz olması
Deviation from Standard (TS EN 81-1 + A3 / TS EN 81-2 + A3 Madde 6.3.3.1)

Yapılan Faaliyet : Yazılı ve görsel uyarı asılmıştır.Kullanılması için baret
Performed Activity konulmuştur.Çalışma alanı ve geçiş yolu üzeri yumuşak malzeme ile kaplanmıştır.

Onay Şartları : Bu belge kuruluşa, makine dairesi çalışma alanı yüksekliğinin
Terms of Approval 1500 mm-1990 mm arasındaki yüksekliğe kadar ve geçiş yolu yüksekliğinin de 1000 mm-1790 mm arasında onaylanan faaliyetlerin yerine getirilmesi kaydıyla düzenlenmiştir. Onaylanmış kuruluşumuzun onayına gerek olmaksızın piyasaya arz yetkisi verilmiştir.

AB Tasarım İnceleme Belgesinin ayrılmaz parçası olan muayene raporu LD-16120518 inceleme bulgularını ve onaylanan tasarım tanımlamasını içerir. Belgenin geçerliliği, muayene raporunda belirtilen dokümanların ve yapılan tasarımın geçerliliğine bağlıdır. İş bu belge aşağıda bilgileri verilen Modül H belgesi ile birlikte geçerlidir.

Inspection Report LD-16120518 an integral part of the EU Design Examination Certificate, includes examination results and the approved design description. This certificates is valid together with the Module H certificate detailed below.

Yayın Tarihi : 11.01.2017
Issue Date

Geçerlilik Tarihi : 10.01.2020
Validity Date

Örnek Asansöre Ait Rapor No : LD-16120518
Report No of Model Lift

Modül H1 (Ek XII) Belge No : 2195-LD-1701106
Modul H1 (Annex XII) Certificate No



FR.LD.45 R:00